

Commonwealth of Kentucky
Division for Air Quality
EXECUTIVE SUMMARY

PROPOSED
TITLE V PERMIT NO. V-03-052 R1
CORNING, INCORPORATED
680 EAST OFFICE STREET, HARRODSBURG, KENTUCKY
FEBRUARY 20, 2008
MARTHA M. ALLMAN, REVIEWER
SOURCE I.D. #: 21-167-00004
SOURCE A.I. #: 3143
ACTIVITY ID #: APE20070001

CURRENT PERMITTING ACTION:

On July 20, 2007, an application was received from Corning, Inc. to add nine emergency diesel generators and one emergency diesel air compressor to its existing Title V permit, V-03-052. These units will only be used during a power failure, which Corning, Inc. estimates not to exceed 55 hours per year for the generators and 52 hours per year for the air compressor. The application was filed as a minor revision, but upon review, the Division determined that pursuant to 401 KAR 52:020 Section 14(d), this application should be processed as a major revision since a federally enforceable emissions cap is involved.

PUBLIC AND AFFECTED STATE REVIEW:

On January 10, 2008, the public notice on availability of the draft permit and supporting material for comments by persons affected by the plant was published in *The Harrodsburg Herald* in Harrodsburg, Kentucky. The public comment period expired 30 days from the date of publication. No other states are affected by this permit action.

No comments were received during this period. The final determination of this Division is that the proposed operation will comply with all air quality regulations and requirements. The permit is now being issued as proposed. A final permit will be issued after the U.S. EPA's 45-day review.